

GOVERNMENT OF MIZORAM
OFFICE OF THE SUPERINTENDING ENGINEER : MIZORAM SLDC CIRCLE
P&E DEPARTMENT : AIZAWL, MIZORAM

e-mail : msldc.circle@gmail.com

Telephone/Telefax : 0389-2311397

No.T.16012/01/26(A)-SE(SLDC)/77

Dated Aizawl, the 14th September, 2026

To,

✓ The Superintending Engineer,
Lunglei Power Circle
Lunglei, Mizoram

Subj : Approval for planned shutdown.

Ref : 1. E-in-C (P&E) letter No.T.16019/01/19-EC(P)/Com/59 Dt.15/02/2020
2. No.S.11011/2/25-SE(LPC)/T/120 Dt.11/09/2026

Sir,

This is to convey an approval for planned shutdown of 132kV line Kawmzawl to Lungsen for erection of 132kV Transmission tower w.e.f 16th to 19th September, 2026 and for stringing of 132kV line Panther Conductor w.e.f 21st to 26th September, 2026 during 9:45 AM to 6:00PM as per detailed programme/ schedule in the annexure enclosed.

Shutdown should be taken strictly in compliance to the general guidelines circulated by Engineer-in-Chief, P&ED vide letter under reference No.1 above and the note indicated in the annexure enclosed herewith.

Further, the concerned circle shall be responsible for timely taking of shutdown and timely release of shutdown.

Enclo: As stated

Yours faithfully,


(LALTHANZUALA)

Superintending Engineer, P&ED
Mizoram SLDC Circle, Aizawl

Memo No.T.16012/01/26(A)-SE(SLDC)/77

Dated Aizawl, the 14th September, 2026

Copy to :-


1. The Engineer-in-Chief, P&ED for favour of kind information.
2. The Chief Engineer, System Operation P&ED for favour of kind information.
3. The Executive Engineer, PMD-I/ PMD-II, Lunglei/ Lawngtlai Power Division for information.
4. The Executive Engineer, Mizoram SLDC Division for information and necessary action. He is requested to monitor that time schedule is maintained strictly by executing agency / Division and maintain proper record of shutdown duration.
5. The Mizoram SLDC Control Room for information.
6. The I.T Cell, Office of the Engineer-in-Chief, P&ED for publishing at departmental website.


Superintending Engineer, P&ED
Mizoram SLDC Circle, Aizawl

APPROVAL FOR PLANNED SHUTDOWN OF POWER NETWORKS

Sl. No	Date of Shutdown	Name of Sub-Station/Feeder	Shutdown Period	Duration (Hrs)	Approximate hourly demand of the areas to be affected			Works to be executed	Affected network
					from	to	Mw		
1	2	3	4	5	6	7	8	9	10
1	16.09.2026 (Wednesday)				9:45AM	10:00AM	0		
2	17.09.2026 (Thursday)				10:00AM	11:00AM	0		
3	18.09.2026 (Friday)				11:00AM	12:00Noon	0		
4	19.09.2026 (Saturday)				12:00Noon	1:00PM	0		
5	21.09.2026 (Monday)								
6	22.09.2026 (Tuesday)	132kV line Kawmzawl to Lungsen.	9:45Am to 6:00Pm	09:15	1:00PM	2:00PM	0	Erection of Transmission Tower & Stringing of 132kV Panther Conductor	Nil. Power shall be drawn from 33kV line Bungtlang - Chawnhu within permissible limits.
7	23.09.2026 (Wednesday)				2:00PM	3:00PM	0		
8	24.09.2026 (Thursday)				3:00PM	4:00PM	0		
9	25.09.2026 (Friday)				4:00PM	5:00PM	0		
10	26.09.2026 (Saturday)				5:00PM	6:00PM	0		

- (a) **Publicity** : Wide publicity should be made by SE, LPC/EE, PMD-II to the affected areas/consumers including those beyond his jurisdiction through electronics and print media, if any.
- (b) **Time schedule** : It should be strictly adhered to the shutdown period and timing granted as above to avoid inconveniences to the consumers.
- (c) **Monitoring of shutdown** : Shutdown and subsequent release of power should be carried out in close co-ordination with SLDC/ Control 'A' Station and other concerned stations.
- (d) All necessary precautionary measures should be taken by all concerned officers/staff to avoid accident especially at the time of execution and release of shutdown.
- (e) Procedure for shutdown and release : The concerned SE's are requested to involved personally for taking shutdown and at the time of releasing shutdown. In case of works performed by two or more groups, the concerned SE's are requested to involved for taking shutdown and releasing of the same separately.


Superintending Engineer, P&ED
Mizoram SLDC Circle, Aizawl