

GOVERNMENT OF MIZORAM
OFFICE OF THE SUPERINTENDING ENGINEER : P&ED
MIZORAM SLDC CIRCLE : P&E OFFICE COMPLEX
MIZORAM : AIZAWL

e-mail : msldc.circle@gmail.com

Telephone /Telefax : 0389-2311397

No.T.16012/01/19-SE(SLDC)/136

Dated Aizawl, the 21st February, 2020

To,

The Superintending Engineer,
Project Circle - I
Power & Electricity Department

Subj : Approval for planned shutdown of 132kV Bawktlang – Tuirial Line.

Ref : 1) E-in-C (P&E) letter No.T.16019/01/15-EC(P)/Com/15 Dt.09/11/16.
2) Your letter No. T-17016/1/2016-SE PC-I/81 Dt. 16/1/20.

Sir,

This is to convey approval for shut down of 132kV Bawktlang – Tuirial Line on 24th February 2020 to 14th March 2020 (20 days) from 9:00 AM to 3:00 PM as per detailed programme / schedule in the annexure enclosed.yu

Shutdown should be taken strictly in compliance to the general guidelines circulated by Engineer-in-Chief, P&ED vide the letter under reference above and the note indicated in the annexure.

Further, the concerned circle shall be responsible for timely taking of shutdown and timely release of shutdown.

Yours faithfully,

Enclo : As stated.

(LALBIAKSANGA)


Superintending Engineer, P&ED
Mizoram SLDC Circle, Aizawl

Dated Aizawl, the 21st February, 2020

Memo No.T. 16012/01/19-SE(SLDC)/136

Copy to :-

1. The Secretary, P&ED for favour of information.
2. The Engineer-in-Chief, P&ED for favour of information.
3. The Chief Engineer, Distribution for favour of information.
4. The Executive Engineer, Kolasib Power Division, Kolasib for information and necessary action.
5. The Executive Engineer, Mizoram SLDC Division for information and necessary action. He is requested to ensure that time schedule is maintained strictly by executing agency / Division and maintain proper record of shutdown duration.
6. The I.T Cell, Office of the Engineer-in-Chief, P&ED for information.
7. The Mizoram SLDC Control Room for information.


Superintending Engineer, P&ED


APPROVAL FOR PLANNED SHUTDOWN OF POWER NETWORKS

Annexure

Sl. No	Date of shutdown	Name of Sub-Station/ feeder	Time of shutdown (hrs)			Works to be executed	Affected networks
			from	to	duration (in hrs)		
1	2	3	4	5	6	7	8
1	24 th February, 2020 to 14 th March, 2020 20 (twenty) days	132kV Bawktlang Sub-Station – Tuirial Line	9:00 AM	3:00 PM	6 X 20 = 120	Double conductor jumpering at all location (118 Nos.) of Tuirial line	Tuirial Line

Note :

- (b) **Publicity** : Wide publicity should be made by SE, Project Circle-I /EE, Kolasib Power Division to the affected areas/consumers including those beyond his jurisdiction if any, through electronics and print media.
- (b) **Time schedule** : It should be strictly adhered to the shutdown period and timing granted as above to avoid inconveniences to the consumers.
- (c) **Monitoring of shutdown** : Shutdown and subsequent release of power should be carried out in close co-ordination with SLDC/Control 'A' Station and other concerned stations.
- (d) All necessary precautionary measures should be taken by all concerned officers/staff to avoid accident especially at the time of execution and release of shutdown.



(LALBIAKSANGA)

Superintending Engineer, P&ED
Mizoram SLDC Circle, Aizawl