

GOVERNMENT OF MIZORAM
OFFICE OF THE SUPERINTENDING ENGINEER : P&ED
MIZORAM SLDC CIRCLE : P&E OFFICE COMPLEX
MIZORAM : AIZAWL

e-mail : msldc.circle@gmail.com

Telephone / Telefax : 0389-2311397

No.T.16012/01/19-SE(SLDC)/7

Dated Aizawl the, 12th June 2019

To

The Superintending Engineer,
Project Circle - I
Power & Electricity Department

Subj : Approval for planned shutdown of Power Networks.

Ref : 1) E-in-C (P&E) letter No.T.16019/01/15-EC(P)/Com/15 Dt.09/11/16.
2) Your letter No. T-17016/1/2016-SEPC-1/17 Dt. 12/6/19.

Sir,

This is to convey approval for shut down of 132kV Line (charged at 33kV) from Zuangtui to W.Phaileng on 14th June 2019 for replacement of damaged 33kV current Transformer as per detailed programme / schedule in the annexure enclosed.

Shutdown should be taken strictly in compliance to the general guidelines circulated by Engineer-in-Chief, P&ED vide the letter under reference above and the note indicated in the annexure.

Yours faithfully,

Endo : As stated

(LALBIAKSANGA)

Superintending Engineer, P&ED
Mizoram SLDC Circle, Aizawl

Memo No.T. 16012/01/19-SE(SLDC)/7

Dated Aizawl the, 12th June 2019

Copy to :-

1. The Secretary, P&ED for favour of information.
2. The Engineer-in-Chief, P&ED for favour of information.
3. The Chief Engineer, Distribution for favour of information.
4. The Executive Engineer, Mamit Power Division for information and necessary action.
5. The Executive Engineer, Mizoram SLDC Division for information and necessary action. He is requested to ensure that time schedule is maintained strictly by executing agency / Division and maintain proper record of shutdown duration.
6. The I.T Cell, Office of the E-in-C, P&ED for information.

Pa Male
13/6/19

J. K. (S)

Pa upland

18/6/19

Superintending Engineer, P&ED
Mizoram SLDC Circle, Aizawl


APPROVAL FOR PLANNED SHUTDOWN OF POWER NETWORKS

Annexure

Sl. No	Date of shutdown	Name of Sub-Station/ feeder	Time of shutdown (hrs)			Works to be executed	Affected networks
			from	to	duration (in hrs)		
1	2	3	4	5	6	7	8
1	14 th June, 2019 (Friday)	132kV Zuangtui – W.Phaileng	6:00 AM	9:00 AM	3 (three)	Replacement of damaged 33kV current Transformer	33kV Sub-Station W.Phaileng, Mamit and Rawpuichhip including Teirei SHP

Note :

- (a) **Publicity** : Wide publicity should be made by SE, Project Circle-I /EE, Mamit Power Division to the affected areas/consumers including those beyond his jurisdiction if any, through electronics and print media.
- (b) **Time schedule** : It should be strictly adhered to the shutdown period and timing granted as above to avoid inconveniences to the consumers.
- (c) **Monitoring of shutdown** : Shutdown and subsequent release of power should be carried out in close co-ordination with SLDC Control 'A' Station and other concerned stations.
- (d) All necessary precautionary measures should be taken by all concerned officers/staff to avoid accident especially at the time of execution and release of shutdown.


 (LALBIAKSANGA)
 Superintending Engineer, P&ED
 Mizoram SLDC Circle, Aizawl