

GOVERNMENT OF MIZORAM  
OFFICE OF THE SUPERINTENDING ENGINEER : P&E : AIZAWL POWER CIRCLE  
CENTRAL BLOCK : P&E OFFICE COMPLEX : AIZAWL

Email: apcmizoram@gmail.com

Ph. No. 0389 2322248 Fax No. 0389 2325330

No.T-22012/04/19-SE(APC)/4

Dated Aizawl, the 1<sup>st</sup> November, 2019

To,

The Executive Engineer, P&E.,  
Generation Division, Aizawl.

**Subject :** Approval for Planned Shutdown of Power Network.

**Reference:** Your No.T-11068/5/2019-EE(GD)/8 dt. 29.10.2019

With reference to letter No. and subject cited above, approval is hereby conveyed for shutdown of 11KV Chaltlang Feeder on 12.11.2019 (Tuesday) from 7:00AM to 5:00PM as per format enclosed.

Shutdown should be taken strictly by observing formalities in compliance to General Guidelines circulated by Engineer-in-Chief, P&ED. You are requested to make wide publicity among consumers to be affected by this shutdown, at the same time to ensure the Power Supply is restore within schedule timing of shutdown.

Encl: As stated

( LALRINMAWIA )

Superintending Engineer, P&E.,  
Aizawl Power Circle, Aizawl.

Memo No.T-22012/04/19-SE(APC)/4

Dated Aizawl, the 1<sup>st</sup> November, 2019

Copy to :

1. The Engineer-in-Chief, P&E., Mizoram, Aizawl for favour of information.
2. The Chief Engineer (System Operation), P&E., Aizawl for favour of information.
3. The Superintending Engineer (SLDC) for favour of information and necessary action with a copy of enclosure.
4. The Executive Engineer, Distribution Division for information.
5. The Sub-Divisional Officer, Revenue Sub-Division-I, for information.
6. IT Cell, Office of the Engineer in Chief for information.

*Lalrinmawia*  
4/11/19  
Superintending Engineer, P&E.,  
Aizawl Power Circle, Aizawl.

Office of the Engineer-in-Chief

Aizawl

Recd. 1


4/11


Superintending Engineer



## Proposal for Planned Shutdown of Power Network

Sl. No.	Proposed		Power Sub-Station/ Line/ Bay, etc proposed for shutdown	Power Sub-Station/ Areas, etc to be affected	Approximate hourly demand of the areas to be affected			Proposed works to be carried out
	Date	Duration (indicating time of shutdown & release)			From	To	MW	
1	2	3	4	5	6	7	8	9
1	12.11.2019 (Tuesday)	7:00AM to 5:00PM (10 Hours)	11kV Chaltlang Feeder	<p>Area fed by 11kV Chaltlang Feeder:</p> <p>Chaltlang Dingdi Veng, Bawngkawn Chhim veng, Bawngkawn Brigade Veng, Bawngkawn to Thuampui</p>	7:00AM	8:00AM	1.17	<p>i) Re-stringing of 11kV Chaltlang Line between Loc.No.6 &amp; Loc.No.7 for stringing of 33kV D/C East-I &amp; East-II Line</p> <p>ii) Stringing of New 33kV D/C East-I &amp; East-II Line between Location No.5 (Pole type - new location) and Location No.6 (existing tower type) at Zuangtui for charging the Line from New 132kV Grid Power Sub-Station, Zuangtui</p> <p>Note: 11kV Chaltlang Feeder/ Line is crossing below new 33kV Double circuit line, i.e. East-I &amp; II Line to be drawn in Zuangtui</p>
					8:00AM	9:00AM	0.99	
					9:00AM	10:00AM	0.91	
					10:00AM	11:00AM	0.72	
					11:00AM	12:00Noon	0.69	
					12:00Noon	1:00PM	0.67	
					1:00PM	2:00PM	0.70	
					2:00PM	3:00PM	0.89	
					3:00PM	4:00PM	1.32	
					4:00PM	5:00PM	1.47	

  
 Sr Executive Engineer, P&E,  
 Generation Division, Aizawl

Approved  
  
 Supt. Engg. P&E,  
 Aizawl Power Circle  
 Aizawl